

# *Annual Drinking Water Quality Report - 2022*

## *Santaquin City*

We're pleased to present to you this year's Annual Drinking Water Quality Report. This report is designed to inform you about the quality of the water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water comes from four springs and two wells that all provide groundwater.

The Drinking Water Source Protection Plan for Santaquin City is available for your review. It contains information about source protection zones, potential contamination sources and management strategies to protect our drinking water. Potential contamination sources common in our protection areas are residential wastewater disposal systems, roads, mining, and agricultural operations. Our sources have a low susceptibility to potential contamination. We have also developed management strategies to further protect our sources from contamination. Please contact us if you have questions or concerns about our source protection plan.

There are many connections to our water distribution system. When connections are properly installed and maintained, the concerns are very minimal. However, unapproved, and improper piping changes or connections can adversely affect not only the availability, but also the quality, of the water. A cross connection may let polluted water or even chemicals mingle into the water supply system when not properly protected. This not only compromises the water quality but can also affect your health. So, what can we do? Do not make or allow improper connections at your homes. Even that unprotected garden hose lying in the puddle next to the driveway is a cross connection. The unprotected lawn sprinkler system after you have fertilized or sprayed is also a cross connection. When the cross connection is allowed to exist at your home it will affect you and your family first. If you'd like to learn more about helping to protect the quality of our water, call us for further information about ways you can help.

I'm pleased to report that our drinking water meets federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Dennis Barnes or Pat Hatfield at (801) 754-3211. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the 1st and 3rd Tuesday at 7 p.m. in the city offices.

Santaquin City routinely monitors for constituents in our drinking water in accordance with the Federal and Utah State laws. The following table shows the results of our monitoring for the period of January 1<sup>st</sup> to December 31<sup>st</sup>2022. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In the following table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

***ND/Low - High*** - For water systems that have multiple sources of water, the Utah Division of Drinking Water has given water systems the option of listing the test results of the constituents in one table, instead of multiple tables. To accomplish this, the lowest and highest values detected in the multiple sources are recorded in the same space in the report table.

***Parts per million (ppm) or Milligrams per liter (mg/l)*** - one part per million corresponds to one minute in

two years or a single penny in \$10,000.

**Parts per billion (ppb) or Micrograms per liter (ug/l)** - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

**Parts per trillion (ppt) or Nanograms per liter (nanograms/l)** - one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

**Maximum Contaminant Level (MCL)** - The “Maximum Allowed” (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** - The “Goal”(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)** - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

TEST RESULTS							
Contaminant	Violation Y/N	Level Detected ND/Low-High	Unit Measurement	MCLG	MCL	Date Sampled	Likely Source of Contamination
<b>Inorganic Contaminants</b>							
Total Coliform Bacteria	N	ND	N/A	0	Presence of coliform bacteria in 5% of monthly samples	2022	Naturally present in the environment
Fecal coliform and <i>E.coli</i>	N	ND	N/A	0	If a routine sample and repeat sample are total coliform positive, and one is also fecal coliform or <i>E. coli</i> positive	2022	Human and animal fecal waste
Turbidity	N	0.32	NTU	0	0.3	2022	Soil runoff
Barium	N	58-72	ppb	2000	2000	2022	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Copper a. 90% results b. # of sites that exceed the AL	N	a. 119 b. 0	ppb	1300	AL=1300	2022	Corrosion of household plumbing systems; erosion of natural deposits
Fluoride	N	254-274	ppb	4000	4000	2022	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories

Lead a. 90% results b. # of sites that exceed the AL	N	a. 3 b. 0	ppb	0	AL=15	2022	Corrosion of household plumbing systems, erosion of natural deposits
Nitrate (as Nitrogen)	N	0.3-0.8	ppm	10	10	2022	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Selenium	N	1-2	ppb	50	50	2022	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Sodium	N	5-8	ppm	None set by EPA	None set by EPA	2022	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills.
Sulfate	N	16-26	ppm	1000	1000	2022	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills, runoff from cropland
TDS (Total Dissolved solids)	N	244-296	ppm	2000	2000	2022	Erosion of natural deposits
Haloacetic Acids	N	4	ppb	0	60	2021	By-product of drinking water disinfection
TTHM [Total trihalomethanes]	N	3-11	ppb	0	80	2022	By-product of drinking water disinfection
Chlorine	N	ND	ppb	4000	4000	2020	Water additive used to control microbes
<b>Radioactive Contaminants</b>							
Alpha emitters	N	ND-2	pCi/l	0	15	2019	Erosion of natural deposits
Radium 228	N	ND-1	pCi/l	0	5	2019	Erosion of natural deposits
Radium 226	N	1	pCi/l	0	5	2011	Erosion of natural deposits

All sources of drinking water are subject to potential contamination by constituents that are naturally occurring or are manmade. Those constituents can be microbes, organic or inorganic chemicals, or radioactive materials. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Santaquin is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have

undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

MCLs are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

We at Santaquin City work around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.